

FATTORI DI CONVERSIONE TRA LE UNITA' DI MISURA

CONVERSION FACTORS AMONG THE UNITS OF MEASUREMENT

DENSITA' NO_x

NO_x Density

	ppm (0%O ₂)	mg/Nm ³ (0%O ₂)	ppm (3%O ₂)	mg/Nm ³ (3%O ₂)	for natural gas				
					mg/kWh NVC	g/MWh NVC	mg/MJ NVC	ng/J NVC	lb/MBTU NVC
ppm (0%O ₂)	1	2.05	0.86	1.76	1.76	1.76	0.49	0.49	1.13x10 ⁻³
mg/Nm ³ (0%O ₂)	0.49	1	0.42	0.86	0.86	0.86	0.24	0.24	0.56x10 ⁻³
ppm (3%O ₂)	1.17	2.40	1	2.05	2.05	2.05	0.57	0.57	1.32x10 ⁻³
mg/Nm ³ (3%O ₂)	0.57	1.17	0.49	1	1	1	0.28	0.28	0.65x10 ⁻³
mg/kWh NVC	0.57	1.17	0.49	1	1	1	0.28	0.28	0.65x10 ⁻³
g/MWh NVC	0.57	1.17	0.49	1	1	1	0.28	0.28	0.65x10 ⁻³
mg/MJ NVC	2.05	4.2	1.76	3.6	3.6	3.6	1	1	2.33x10 ⁻³
ng/J NVC	2.05	4.2	1.76	3.6	3.6	3.6	1	1	2.33x10 ⁻³
lb/MBTU NVC	0.88x10 ³	1.79x10 ³	0.75x10 ³	1.54x10 ³	1.54x10 ³	1.54x10 ³	0.43x10 ³	0.43x10 ³	1